



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

February 14, 2011

In reply refer to:
255446:rsunjed

Mr. Matt Estrin
Associate Director of Facilities
San Diego Wild Animal Park
15500 San Pasqual Valley Road
Escondido, CA 92027-8702

Dear Mr. Estrin:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR
SAN DIEGO ZOO'S SAFARI PARK SEWAGE TREATMENT PLANT**

The California Regional Water Quality Control Board, San Diego Region has reviewed the December 2010 monthly, fourth quarterly 2010, and 2010 annual monitoring reports submitted by the Zoological Society of San Diego in accordance with the Monitoring and Reporting Program of Order No. 99-04.

The following violation of Order No. 99-04 was identified in the submitted report:

1. The daily maximum effluent limitation for chloride of Discharge Specification B.4, established at 400 milligrams per liter (mg/L), was exceeded on December 27, 2010 with a reported value of 1,120 mg/L.

The next monitoring report due is the January 2011 monthly monitoring report. Please submit the monthly report prior to March 1, 2011. For questions pertaining to the subject matter, please contact Ray Sunjed at (858) 627-3977 or via email at rsunjed@waterboards.ca.gov.

**PLEASE INCLUDE "255446:RSUNJED" IN THE SUBJECT LINE OF FUTURE
CORRESPONDANCE.**

Sincerely,

Ben Tobler
Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure #: 377526
Violation ID #: 890665